



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

## DEPARTMENT OF NATURAL RESOURCES

[www.dnr.mo.gov](http://www.dnr.mo.gov)

August 31, 2015

CERTIFIED MAIL #7014 1820 0001 6466 3429  
RETURN RECEIPT REQUESTED

### NOTICE OF VIOLATION

The Honorable John Best, Mayor  
City of Bolivar  
345 S. Main Avenue  
Bolivar, MO 65613

RE: MISSOURI STATE OPERATING PERMIT NUMBER **MO0022373**

Dear Mayor Best:

A review of your Discharge Monitoring Report(s) (DMR) was conducted by the Department of Natural Resources (department). The monitoring period ending in **June 2015** shows that the effluent limitations established in your Missouri State Operating Permit (MSOP) have been exceeded. A **Notice of Violation (NOV)** is being issued for exceedances listed below according to your (MSOP) **MO0022373**. The effluent limits and the values that have exceeded those effluent limits are listed below.

Outfall	Months	Parameter	Permit Limitations	Reported Values
001	06/2015	E Coli	206 MPN/100 mL monthly average	1024 MPN/100 mL
001	06/2015	Ammonia as N	1.4 mg/L monthly average 3.7 mg/L daily maximum	6.7 mg/L 6.7 mg/L

An exceedance of the effluent limitations established in your permit is a violation of the Missouri Clean Water Law, Section 644.051.1(3) and 644.076.1, Clean Water Commission Regulation 10 CSR 20-7 and your MSOP. Permittee failed to comply with effluent limits contained in Part "A" of the Missouri State Operating Permit number MO0022373. Permittee exceeded effluent limitations for E Coli and Ammonia as N for the month of **June 2015**. The facility is responsible for taking appropriate steps to eliminate the violation(s).

Bolivar WWTF  
August 31, 2015  
Page 2

**Please provide a written response within 30 calendar days of receipt of this letter to the Department of Natural Resources (department) which explains the reason(s) for the noncompliance and what steps your operation has taken or will take to prevent a reoccurrence of the violation(s).** The facility will be considered in noncompliance with the violation(s) and our files will reflect the continued noncompliance until the documentation is submitted to this office. If you have already provided this information to the department, you may disregard this request.

We appreciate your cooperation and immediate attention so that violations can be corrected. If you have questions please contact water pollution staff by calling 417-891-4300 or via mail at Missouri Department of Natural Resources, Southwest Regional Office, 2040 W. Woodland, Springfield, Missouri 65807-5912.

Sincerely,

SOUTHWEST REGIONAL OFFICE



Cynthia S. Davies  
Regional Director

CSD/rcg